



SLUCE VALVE BRICKWALL CHAMBER WITH MS PIPE ARRANGEMENT

SLUCE VALVE BRICKWALL CHAMBER WITH DI PIPE ARRANGEMENT (TYPE A)

SLUCE VALVE BRICKWALL CHAMBER WITH uPVC & mPVC PIPE ARRANGEMENT

SLUCE VALVE BRICKWALL CHAMBER SCHEDULE				
PIPE ND (mm)	L (mm)	L1 (mm)	L2 (mm)	SLUCE VALVE DIA. (mm)
100	900	400	600	100
150	1000	400	600	150
200	1000	500	680	200
250	1100	500	700	250
300	1100	550	700	300
400	1200	600	800	400
450	1200	600	800	450

- NOTE:
- 1) ALL DIMENSIONS ARE IN MILLIMETRE AND LEVELS IN METRE UNLESS OTHERWISE STATED.
 - 2) ALL CONCRETE TO BE GRADE 25 UNLESS OTHERWISE STATED.
 - 3) ALL GRAVEL SOAKAWAY TO BE WRAPPED WITH TWO LAYERS OF APPROVED FILTER CLOTH.
 - 4) THE uPVC DRAIN PIPE AND SOAKAWAY SHALL ONLY BE PROVIDED IF THE GROUND WATER TABLE IS LOWER THAN THE INVERT LEVEL OF THE CHAMBER AS DIRECTED BY THE SO.
 - 5) BRICKWALL CHAMBERS TO BE USED IN LOCATIONS NOT SUITABLE FOR PRECAST CHAMBERS AS DIRECTED BY S.O
 - 6) FOR DETAILS OF PC SLAB COVER AND CAPPING BEAM REFER DRG. No. SA/STD/CH/02



SAJ Holdings Sdn Bhd. (478718-H)
 Jalan Garuda, Larkin, P.O Box 282,
 80350 Johor Bahru, Johor, Malaysia
 T. +607 - 224 4040 F. +607 - 224 0033
 1800-86-7474 ssm 018-772 7474 www.saj.com.my customer.care@saj.com.my

PROJECT :

DRAWING TITLE :

DETAILS OF BRICKWALL SLUCE VALVE CHAMBER

DRAWN BY : MAZZ DESIGNED : WJC

CHECKED : MFB APPROVED : T.C

SCALE : NOT TO SCALE DATE : DECEMBER 2013

DRAWING NO : SAJ/STD/CH/05

REV.	REVISION BY	DESCRIPTION	DATE