



- NOTE:
- 1) ALL DIMENSIONS ARE IN MILLIMETRE AND LEVELS ARE IN METRE UNLESS OTHERWISE STATED
 - 2) ALL CONCRETE TO BE GRADE 25 UNLESS OTHERWISE STATED.
 - 3) ALL GRAVEL, SOAKAWAY TO BE WRAPPED WITH TWO LAYERS OF APPROVED FILTER CLOTH.
 - 4) THE UPVC DRAIN PIPE AND SOAKAWAY SHALL ONLY BE PROVIDED IF THE GROUND WATER TABLE IS LOWER THAN THE INVERT LEVEL OF THE CHAMBER AS DIRECTED BY THE S.O.
 - 5) FOR RC DETAILS OF PRECAST CHAMBER, REFER DRG. No. SAJ/STD/CH/02
 - 6) BRICKWALL CHAMBER TO BE USED IN LOCATIONS NOT SUITABLE FOR PRECAST CHAMBERS AS DECIDED BY S.O.
 - 7) FOR DETAILS OF PC SLAB COVER REFER DRG. No. SAJ/STD/CH/02

REV.	REVISION BY	DESCRIPTION	DATE



SAJ Holdings Sdn Bhd. (478718-H)
 Jalan Garuda, Larkin, P.O. Box 282,
 60350 Johor Bahru, Johor, Malaysia
 T: +607-224 4040 F: +607-224 0033
 1800-987474 sng.0187272474 www.saj.com.my customer.care@saj.com.my

PROJECT:
 DRAWING TITLE:
DETAILS OF FIRE HYDRANT & CHAMBER (DI & MS PIPE)

DRAWN BY : MAZZ
 CHECKED : MFB
 SCALE : NOT TO SCALE
 DATE : DECEMBER 2013
 DRAWING NO : SAJ/STD/CH/07