



- NOTE:
- 1) ALL DIMENSIONS ARE IN MILLIMETRE AND UNLESS OTHERWISE STATED.
 - 2) ALL CONCRETE TO BE GRADE 25 UNLESS OTHERWISE STATED.
 - 3) ALL GRAVEL SOAKAWAY TO BE WRAPPED WITH TWO LAYERS OF APPROVED FILTER CLOTH.
 - 4) THE UPVC DRAIN AND SOAKAWAY SHALL ONLY BE PROVIDED IF THE GROUND WATER TABLE IS LOWER THAN THE LEVEL OF THE CHAMBER AS DIRECTED BY THE S/O
 - 5) FOR DETAIL OF PC SLAB COVER AND CAPPING BEAM, REFER DRG. No. SA/H / SD / ch / 01

REV.	REVISION BY	DESCRIPTION	DATE



SAJ Holdings Sdn Bhd. (478718-H)
 Jalan Garuda, Larkin, P.O Box 282,
 80350 Johor Bahru, Johor, Malaysia
 T +607 - 224 4040 F +607 - 224 0033
 1800-88-7474 sms 018-772 7474 www.saj.com.my customer.care@saj.com.my

PROJECT :
 DRAWING TITLE :
**DETAILS OF AIR VALVE AND SLUICE VALVE
 BRICKWALL CHAMBER FOR TWIN PIPES**

DRAWN BY : MAZZ	DESIGNED : W.C
CHECKED : MRB	APPROVED : T.C
SCALE : NOT TO SCALE	DATE : DECEMBER 2013
DRAWING NO : SAJ/STD/CH/12	