



- NOTE:
1. P.A (POLYETHYLENE ALUMINIUM).
  2. ALL PIPE MATERIALS AND BRASS SPECIALS TO SPAN APPROVAL.
  3. SIZE OF G.I SLEEVE CLASS 'B' MUST BE ONE GRADE HIGHER FROM THE COMM PIPE SPECIFIED.
  4. STAINLESS STEEL PIPE SHOULD BE OF GRADE 304 REINFORCEMENT TO COMPLY BS 4449 : R WITH  $t_y = 250 \text{ N/mm}^2$ .
  5. MINIMUM DEPTH IS 300MM UNDER SITE TABLE AND 450MM UNDER METALLED ROAD
  7. NO SLEEVE IS REQUIRED IF IMPACT MOLLING OR MANUAL BACKHOE INSERTION METHOD IS USE
  8. IF COMMUNICATION PIPE LAYING AT SAND BASE G.I SLEEVE NOT REQUIRED
  9. IF COMMUNICATION PIPE LAYING AT CRUSHER RUN BASE :- G.I SLEEVE REQUIRED

REV.	REVISED BY	DESCRIPTION	DATE



**SAJ Holdings Sdn Bhd.** (476718 - H)  
 Jalan Garuda, Larkin, P.O Box 882  
 80350 Johore Bahru, Johor, Malaysia  
 T. +607 - 224 4040 F. +607 - 224 0033

1800-86-9474 sms 019-772 7474 www.saj.com.my customer.care@saj.com.my

PROJECT :  
 DRAWING TITLE :  
**DETAILS OF P.A COMMUNICATION PIPE AT METALLED ROAD**

DRAWN BY : MAZZ DESIGNED : W.C  
 CHECKED : MFB APPROVED : T.C  
 SCALE : NOT TO SCALE DATE : DECEMBER 2013  
 DRAWING NO : SAJ/STD/COM/01